



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Marysville

**School Name:** Allen Creek Elementary

**School Code:** 4454

**School Address:** 6505 60th Dr Northeast, Marysville Washington 98270

**Number of Samples Collected:** 74

**Date Collected:** 05/24/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24516	other	other		<1	06/24/2019	06690, 6:17 AM
24611	FirstDraw	Tap	Health Room	2	06/24/2019	
24612	FirstDraw	Bubbler	Pod A	8	06/24/2019	Some mineral deposits on bubbler
24613	FirstDraw	Tap	Pod A	TB	NA	No Aerator
24614	FirstDraw	Bubbler	Room A1	1	06/24/2019	
24615	FirstDraw	Tap	Room A1	<1	06/24/2019	
24616	FirstDraw	Bubbler	Room A2	1	06/24/2019	
24617	FirstDraw	Tap	Room A2	1	06/24/2019	
24618	FirstDraw	Bubbler	Room A3	<1	06/24/2019	Mineral deposits on bubbler
24619	FirstDraw	Tap	Room A3	1	06/24/2019	
24620	FirstDraw	Tap	Kitchen	1	06/24/2019	Sink in middle of room
24621	FirstDraw	Tap	Speech Language Therapy Room	4	06/24/2019	
24622	FirstDraw	Bubbler	Room A4	<1	06/24/2019	
24623	FirstDraw	Tap	Room A4	1	06/24/2019	
24624	FirstDraw	Bubbler	Room A5	TB	NA	Water dribbles out, low pressure
24625	FirstDraw	Tap	Room A5	2	06/24/2019	
24626	FirstDraw	Bubbler	Room A6	TB	NA	
24627	FirstDraw	Tap	Room A6	<1	06/24/2019	
24628	FirstDraw	Bubbler	B Pod	TB	NA	Rust around spout, slightly discolored water
24629	FirstDraw	Tap	B Pod	TB	NA	No aerator, slightly discolored

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24630	FirstDraw	Bubbler	Room B1	1	06/24/2019	
24631	FirstDraw	Tap	Room B1	TB	NA	Dropped cap to bottle, no aerator
24632	FirstDraw	Bubbler	Room B2	<1	06/24/2019	
24633	FirstDraw	Tap	Room B2	4	06/24/2019	
24634	FirstDraw	Bubbler	Room B3	<1	06/24/2019	South Wall of Room
24635	FirstDraw	Tap	Room B3	<1	06/24/2019	Rust around aerator, Sink on south wall
24636	FirstDraw	Bubbler	Room B3	TB	NA	East Wall
24637	FirstDraw	Tap	Room B3	TB	NA	East Wall, discolored water
24638	FirstDraw	Bubbler	Room B4	TB	NA	
24639	FirstDraw	Tap	Room B4	TB	NA	
24640	FirstDraw	Bubbler	Room B5	<1	06/24/2019	
24641	FirstDraw	Tap	Room B5	<1	06/24/2019	
24642	FirstDraw	Bubbler	Room B6	TB	NA	
24643	FirstDraw	Tap	Room B6	1	06/24/2019	
24644	FirstDraw	Bubbler	Room F3	TB	NA	
24645	FirstDraw	Tap	Room F3	TB	NA	Water discoloration
24646	FirstDraw	Tap	Library Office	TB	NA	
24647	FirstDraw	Bubbler	Outside Gym	<1	06/24/2019	Left Fountain
24648	FirstDraw	Bubbler	Outside Gym	<1	06/24/2019	Right Fountain
24649	FirstDraw	Tap	Room G2	1	06/24/2019	
24650	FirstDraw	Bubbler	C Pod	TB	NA	Mineral deposits on bubbler
24651	FirstDraw	Tap	C Pod	TB	NA	
24652	FirstDraw	Bubbler	Room C1	<1	06/24/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24653	FirstDraw	Tap	Room C1	TB	NA	
24654	FirstDraw	Bubbler	Room C2	<1	06/24/2019	
24655	FirstDraw	Tap	Room C2	TB	NA	No Aerator
24656	FirstDraw	Tap	Room C3	TB	NA	No Aerator, all other fixtures off, on East Wall
24657	FirstDraw	Bubbler	Room C4	TB	NA	Very discolored water, on West Wall
24658	FirstDraw	Tap	Room C4	TB	NA	West Wall
24659	FirstDraw	Bubbler	Room C4	1	06/24/2019	South Wall, low pressure, dribbles out
24660	FirstDraw	Tap	Room C4	TB	NA	South Wall
24661	FirstDraw	Bubbler	Room C5	TB	NA	Weak flow, very discolored water
24662	FirstDraw	Tap	Room C5	TB	NA	
24663	FirstDraw	Bubbler	Room C6	TB	NA	
24664	FirstDraw	Tap	Room C6	TB	NA	
24665	FirstDraw	Bubbler	D Pod	TB	NA	Dribbles out, low pressure
24666	FirstDraw	Tap	D Pod	TB	NA	
24667	FirstDraw	Bubbler	Room D1	<1	06/24/2019	
24668	FirstDraw	Tap	Room D1	<1	06/24/2019	
24669	FirstDraw	Bubbler	Room D2	<1	06/24/2019	
24670	FirstDraw	Tap	Room D2	1	06/24/2019	
24671	FirstDraw	Bubbler	Room D3	2	06/24/2019	
24672	FirstDraw	Tap	Room D3	TB	NA	
24673	FirstDraw	Bubbler	Room D4	2	06/24/2019	
24674	FirstDraw	Tap	Room D4	TB	NA	

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
24675	FirstDraw	Bubbler	Room D5	2	06/24/2019	
24676	FirstDraw	Tap	Room D5	TB	NA	
24677	FirstDraw	Bubbler	Room D6	<1	06/24/2019	
24678	FirstDraw	Tap	Room D6	<1	06/24/2019	
24679	FirstDraw	WaterCooler	Portable 4	<1	06/24/2019	
24680	FirstDraw	WaterCooler	Portable 5	<1	06/24/2019	
24681	FirstDraw	WaterCooler	Portable 6	<1	06/24/2019	
24682	FirstDraw	WaterCooler	Portable 7	<1	06/24/2019	
24683	FirstDraw	WaterCooler	Portable 3	<1	06/24/2019	